

बुक संख्या D 3431 जल-कल विभाग, नगर निगम, प्रयागराज (नगद प्राप्ति रसीद)

श्री/श्रीमती सुहेल देवी मुहल्ला

क.सं. म.सं. अवशेष



वार्ड सं० से प्राप्त किया।

3409

3409

देव तिथि खाना सं०

मीटर सं० ले.फो. सं०

3409

(केवल कार्यालय प्रयोग हेतु)

लेजर सं०

के पृष्ठ सं०

पर जमा की प्रविष्टि की गयी।

अधिग्रमाणित

लेखा पदाधिकारी

कुल योग (शब्दों में) रु०

रसीद बनाने वाले का

दिनांक : 19/04/24

# ALLAHABAD JAL KAL VIBHAG LABORATORY

Result of the Bacteriological examination of the Water taken from Water Sample  
 Name & Designation of the person collecting the sample SHAMBA

S.No.	Date & time of collection	Date of receipt and inoculation	Source of Sample	Colony Count on agar plate in 1 ml.		Presumptive coliform count	Probable No. of coliform organism in 100 ml. of original water	Free residual chlorine mg/l	Remarks
				At 37°C in 48 hours	At room temperature in 72 hours				
15-4-2024	15/4/2024		Water Sample, ग्रामिण भांडों से ग्रामों वाले दो पहा प्रयोगशाला	0	0	0	0	Nil	Excellent

  
Chemist

Analyst

  
Ex. Engineer (HQ)  
[P.T.O.]  
अधिराणी अभियन्ता (मु०)  
जनकल विभाग, नगर निगम  
प्रयागराज



# PRAYAGRAJ JAL KAL VIBHAG LABORATORY

## CHEMICAL ANALYSIS OF WATER

### Test Report

कार्यालय महाप्रबन्धक

जलकल विभाग, नगर निगम  
प्रयागराज

संख्या 06 म.प्र.ज.क.वि./2024-25  
दिनांक 19-04-2024

Sl. NO

1. Source of sample *Water Sample, Police modern School, 4th Vahini P.A.C.*
2. Date of Sampling *15/4/2024 Received. Prayagraj*
3. Date of Analysis *15/4/2024*

Physico Chemical Parameter	BIS Limits IS 10500 : 2012		Result of test
	Requirement (Desirable Limit) Mg/l	Permissible limit In the absence of Alternate source Mg/l	
4. Total Dissolved solid	500	2000	350
5. Total Hardness (as CaCO <sub>3</sub> )	200	600	152
6. Sulphate (as SO <sub>4</sub> )	200	400	98
7. Sulphide (as H <sub>2</sub> S)	0.05	No relaxation	Nil
8. Chloride (as Cl)	250	1000	118
9. Total Alkalinity (as CaCO <sub>3</sub> )	200	600	102
10. Nitrite (as NO <sub>2</sub> )	NS	NS	Nil
11. Nitrate (as NO <sub>3</sub> )	45	No relaxation	15
12. Iron (as Fe)	0.3	No relaxation	0.1
13. Fluoride (as F)	1.0	1.5	0.6
14. Colour Hazen Unit	5	15	Colourless
15. Taste	Agreeable	Agreeable	Not Tasted
16. Odour	Agreeable	Agreeable	Odourless
17. pH Value	6.5 to 8.5	No relaxation	7.0
18. Ammonia (as total Ammonia -N)	0.5	No relaxation	0.01
19. Dissolved Oxygen	Minimum 5.0	NS	5.6
20. Free Residual Chlorine	0.2	1	Nil
21. Turbidity N.T.U	1	5	1.2
22. Temperature	NS	NS	—
23. Mineral Oil	0.5	No relaxation	—
24. Conductivity (as $\mu$ S/cm)	NS	NS	500

NS=Not Specified

Remarks

*Potable*

Chemist

अधिरासी अधिकारी (मु०)  
जलकल विभाग, नगर निगम  
प्रयागराज

#### Copy forwarded for information to

1. The addl. Director, State Health Institute, Sector-C, Chetan Bihar, Aliganj, Lucknow, U.P.
2. Chief Medical Officer, Prayagraj.
3. Mukhya Nagar Swasthya Adhikari, Nagar Nigam. Prayagraj.
4. Nagar Ayukta, Nagar Nigam, Prayagraj.
5. The Suprintending Engineer (R&D) office of Addl. Chief Engineer (PPR&D), U.P. Jal Nigam, 6 Rana Pratap marg, Lucknow.
6. Chairman, Jal Kal Vibhag/Mayor, Nagar Nigam, Prayagraj.

E.E.

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 16/4/2024

It is certified that an inspection team headed by Er. Shivam Mishra, Executive Engineer (PHED)

(Name of Officers with designation) from Talukal Vibhag Nagar Nigam Prayagraj

inspected the Police Modern school 4th Bahini P.A.C. Prayagraj

(Name & Address of the school) on 16/4/2024 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Chemical & Bact. Report dated 15/4/2024  
86 dt. 19-4-2024

of Lab. Talukal Vibhag Prayagraj (PHED Lab) certified that

the Police Modern School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six month only.

Signature with Seal: [Signature]

Name

Designation

Name & Address of the Office / Department: Prayagraj E.E. (PHED)

To

Semanagar  
4th Bahini P.A.C.

(Name & Address of the Institution)

Prayagraj

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies